



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Otsego Northern Catskills BOCES

Project Name: Oneonta School District

Joshua Reiss  
31 Center Street  
Oneonta, NY 13820

Project / PO Number: 16-02496  
Received: 09/23/2016 00:00  
Reported: 12/28/2016 19:27

Analytical Testing Parameters

Client Sample ID: A1  
Lab Sample ID: J6J0133-01  
Sample Type: Grab

Collected By: JR-Client  
Collection Date: 09/16/16  
Collection Time: 06:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.00100	0.0150	0.00100	mg/L		12/06/16 1731	12/07/16 1826

Analytical Testing Parameters

Client Sample ID: A2  
Lab Sample ID: J6J0133-02  
Sample Type: Grab

Collected By: JR-Client  
Collection Date: 09/16/16  
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.00100	0.0150	0.00100	mg/L		12/06/16 1731	12/07/16 1827

Analytical Testing Parameters

Client Sample ID: A3  
Lab Sample ID: J6J0133-03  
Sample Type: Grab

Collected By: JR-Client  
Collection Date: 09/16/16  
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.00100	0.0150	0.00100	mg/L		12/06/16 1731	12/07/16 1827



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: A4
Lab Sample ID: J6J0133-04
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1828

Analytical Testing Parameters

Client Sample ID: A5
Lab Sample ID: J6J0133-05
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00211, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1829

Analytical Testing Parameters

Client Sample ID: A6
Lab Sample ID: J6J0133-06
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00102, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1831



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: A7
Lab Sample ID: J6J0133-07
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0274, 0.0150, 0.00100, mg/L, G, 12/06/16 1731, 12/07/16 1831

Analytical Testing Parameters

Client Sample ID: A8
Lab Sample ID: J6J0133-08
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00521, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1833

Analytical Testing Parameters

Client Sample ID: B1
Lab Sample ID: J6J0133-09
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00764, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1834



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: B2
Lab Sample ID: J6J0133-10
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1835

Analytical Testing Parameters

Client Sample ID: B3
Lab Sample ID: J6J0133-11
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1837

Analytical Testing Parameters

Client Sample ID: B4
Lab Sample ID: J6J0133-12
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1752



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: B5
Lab Sample ID: J6J0133-13
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00130, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1837.

Analytical Testing Parameters

Client Sample ID: B6
Lab Sample ID: J6J0133-14
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0405, 0.0150, 0.00100, mg/L, G, 12/06/16 1731, 12/07/16 1838.

Analytical Testing Parameters

Client Sample ID: B7
Lab Sample ID: J6J0133-15
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/21/16
Collection Time: 06:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0272, 0.0150, 0.00100, mg/L, G, 11/23/16 1832, 11/29/16 1752.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: B9
Lab Sample ID: J6J0133-16
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/21/16
Collection Time: 06:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00907, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1753

Analytical Testing Parameters

Client Sample ID: B10
Lab Sample ID: J6J0133-17
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/21/16
Collection Time: 06:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00609, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1839

Analytical Testing Parameters

Client Sample ID: B11
Lab Sample ID: J6J0133-18
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1754



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: B12
Lab Sample ID: J6J0133-19
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00208, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1839.

Analytical Testing Parameters

Client Sample ID: B13
Lab Sample ID: J6J0133-20
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1841.

Analytical Testing Parameters

Client Sample ID: B14
Lab Sample ID: J6J0133-21
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1843.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: B15
Lab Sample ID: J6J0133-22
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1756

Analytical Testing Parameters

Client Sample ID: B16
Lab Sample ID: J6J0133-23
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00161, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1844

Analytical Testing Parameters

Client Sample ID: B17
Lab Sample ID: J6J0133-24
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00165, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1845





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: B18
Lab Sample ID: J6J0133-25
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00481, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1845

Analytical Testing Parameters

Client Sample ID: B19
Lab Sample ID: J6J0133-26
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00212, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1847

Analytical Testing Parameters

Client Sample ID: C1
Lab Sample ID: J6J0133-27
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1849



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: C2
Lab Sample ID: J6J0133-28
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1850

Analytical Testing Parameters

Client Sample ID: C3
Lab Sample ID: J6J0133-29
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00270, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1850

Analytical Testing Parameters

Client Sample ID: C4
Lab Sample ID: J6J0133-30
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1756



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: C5
Lab Sample ID: J6J0133-31
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1757

Analytical Testing Parameters

Client Sample ID: C6
Lab Sample ID: J6J0133-32
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1758

Analytical Testing Parameters

Client Sample ID: C7
Lab Sample ID: J6J0133-33
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1758



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

Analytical Testing Parameters

Client Sample ID: C8
Lab Sample ID: J6J0133-34
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/06/16 1731, 12/07/16 1851

Analytical Testing Parameters

Client Sample ID: C9
Lab Sample ID: J6J0133-35
Sample Type: Grab

Collected By: JR-Client
Collection Date: 09/16/16
Collection Time: 06:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1759

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MCL: Maximum Contaminant Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, No, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Table with 2 columns: Microbac Laboratories, Inc., New York Division; NY Lab ID No.: 10795; Microbac Laboratories, Inc. - Chicagoland; NY Lab ID No: 12006; PA DEP ID: 68-04863; New York State Department of Health; New York State Department of Health; Pennsylvania Department of Environmental Protection



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0133

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

**Reviewed and Approved By:**

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield  
Division Manager  
12/28/2016 19:27

**Go Green:** Contact Michael Fifield to set up email reporting and invoicing options.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)53-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

**Samples must be returned on ice**

MNY Workorder #



J6J0133

Client Information			Billing/Invoice:		Analysis Requested				Receiving Info (Lab Use Only)	
<b>Name:</b> <b>ONC BOCES</b> <b>Address:</b> 31 Center Onconta, NY 13820 <b>Contact:</b> <b>Josh Reiss</b> <b>Phone:</b> <b>Project:</b> <b>NCOC BOCES</b> <b>Quote ID:</b> PO#			<b>ONC BOCES</b> Date Req:		Ice: YES NO Cooler: YES NO Sample Temp: YES NO Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container Size (in Mi) Preservative				Comments/Field Data	
Sample Information			Date		Time		Matrix		Number of Containers for Analysis Requested	
Description/Location			Date		Time		Type		Comments/Field Data	
1	A1		9/16/16	6:12			Grab	1		
2	A2		9/16	6:13						
3	A3		9/16	6:13						
4	A4		9/16	6:17 AM						
5	A5		9/16	6:18 AM						
6	A6		9/16	6:19 AM						
7	A7		9/16	6:16 AM						
8	A8		9/16	6:16 AM						
9	B1		9/16	6:16						
10	B2		9/16	6:27						
11	B3		9/16	6:23						
12	B4		9/16	6:24						
13	B5		9/16	6:25						
14	B6		9/16	6:26						
15	B7		9/21	6:04						
16	B8									
17	B9		9/21	6:06						
18	B10		9/21	6:06						
19	B11		9/16	6:35						
20	B12		9/16	6:36						

Print Name and Company: **JOSH REISS + SHAWN LOVELESS**  
 Received: **9/23/16 4:15**  
 Received: **Pat Haddock/mc**  
 Comments: **ONE BOCES**

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

**Samples must be returned on ice**

MNY Workorder #

J6J0133

Client Information		Billing/Invoice:	
Name: <b>ONC BOCES</b>		ONC BOCES	
Address: 31 Center Oneonta, NY 13820			
Contact: <b>Josh Reiss</b>			
Phone:			
Project: <b>NCOC BOCES</b>			
Quote ID:		PO#:	
Rush TAT Bus. Days: <2 2-5 5-7 7-10		Date Req.:	
Carbon Copy: Yes			
Email Results: Yes			
Fax Results: Yes			

  

Sample Information			Analysis Requested		Receiving Info (Lab Use Only)		
1	Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data
1	B13	9/16/16	6:37	Grab	1		
2	B14	9/16	6:34				
3	B15	9/16	6:34				
4	B16	9/16	6:33				
5	B17	9/16	6:33				
6	B18	9/16	6:17				
7	B19	9/16	6:18				
8	C1	9/16	6:43				
9	C2	9/16	6:44				
10	C3	9/16	6:44				
11	C4	9/16	6:44				
12	C5	9/16	6:52				
13	C6	9/16	6:53				
14	C7	9/16	6:49				
15	C8	9/16	6:53				
16	C9	9/16	6:51				
17	C10	9/16	6:47				
18	C11	9/16	6:48				
19							
20							

  

Total Lead (EPA 200.8)		Date/Time	
Plastic			
250 ml			
HNO3			
Accepted?	YES NO		
Container Material			
Container Size(in ml)			
Preservative			
Dropoff:	C W		
Pickup:	YES NO		
Cooler Seal:	YES NO		
Sample Temp:			
Cooler:	YES NO		
Ice:	YES NO		

  

Sampled:	Print Name and Company	Date/Time	Comments
Josh Reiss & Shawn Loveless	ONC BOCES	9/23/16	
Received:	Josh Reiss	9/23/16	145
Received:	Josh Reiss	9/23/16	145